1113 Fay Street
Columbia, MO 65201

August 19, 2021

Dear Josh Lehmen:

PDC Laboratories, Inc.

SAMPLE RECEIPT CHECK LIST

Items not applicable will be marked as in compliance

Work Order EH00244

COC present upon sample receipt

ANALYTICAL RESULTS

Sample: EH00244-01
Name: 1. Kitchenette By Room 141
Alias: ASL-H141-KF-1
Sampled: 07/29/21 06:00
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	180	ug/L		1300	08/10/21 14:23	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/10/21 14:23	KMC	EPA 200.8 REV 5.4

Sample: EH00244-02
Name: 2. Womens Restroom Room 163
Alias: ASL-163-RRF-1
Sampled: 07/29/21 06:25
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	90	ug/L		1300	08/10/21 14:24	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/10/21 14:24	KMC	EPA 200.8 REV 5.4

Sample: EH00244-03
Name: 3. Mens Restroom Room 164
Alias: ASL-163-RRF-2
Sampled: 07/29/21 06:25
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	110	ug/L		1300	08/10/21 14:26	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/10/21 14:26	KMC	EPA 200.8 REV 5.4

Sample: EH00244-04
Name: 4. Hall by 162
Alias: ASL-H162-EWC-1
Sampled: 07/29/21 05:57
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	190	ug/L		1300	08/10/21 14:28	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/10/21 14:28	KMC	EPA 200.8 REV 5.4

PDC Laboratories, Inc.

ANALYTICAL RESULTS

Sample: EH00244-05
Name: 5. Room 107
Alias: ASL-107-CF-2

Sampled: 07/29/21 06:03
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
	130	ug/L					

PDC Laboratories, Inc.

ANALYTICAL RESULTS

Sample: EH00244-09
Name: 9. Hall by 107
Alias: ASL-H107-EWC-2

Sampled: 07/29/21 06:17
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	360	ug/L		1300	08/10/21 14:42	KMC	EPA 200.8 REV 5.4
Lead	36	ug/L			08/10/21 14:42	KMC	EPA 200.8 REV 5.4

Sample:
Name:

Sampled:
Received:

ANALYTICAL RESULTS

Sample: EH00244-13
Name: 13. Room 6045 Restroom
Alias: ASL-6045-RRF-5
Sampled: 07/29/21 06:29
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	100	ug/L		1300	08/10/21 14:48	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/10/21 14:48	KMC	EPA 200.8 REV 5.4

Sample: EH00244-14
Name: 14. Room 6046 Restroom
Alias: ASL-6046-RRF-6
Sampled: 07/29/21 06:29
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	120	ug/L		1300	08/10/21 14:55	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/10/21 14:55	KMC	EPA 200.8 REV 5.4

Sample: EH00244-15
Name: 15. Room 6027 Restroom
Alias: ASL-6027-RRF-7
Sampled: 07/29/21 06:37
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	380	ug/L		1300	08/10/21 14:57	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/10/21 14:57	KMC	EPA 200.8 REV 5.4

Sample: EH00244-16
Name: 16. Room 6027 Nurses Office
Alias: ASL-6027-NSF-1
Sampled: 07/29/21 06:37
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	1300	ug/L		**1300	08/12/21 09:32	KMC	EPA 200.8 REV 5.4
Lead	20	ug/L		**15	08/11/21 15:10	KMC	EPA 200.8 REV 5.4

PDC Laboratories, Inc.

ANALYTICAL RESULTS

Sample: EH00244-17
Name: 17. Room 6036 Restroom
Alias: ASL-6036-RRF-8

Sampled: 07/29/21 06:31
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	120	ug/L		1300	08/10/21 14:59	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/10/21 14:59	KMC	EPA 200.8 REV 5.4

Sample: EH00244-18
Name: 18. Room 6059
Alias: ASL-6059-CF-5

Sampled: 07/29/21 06:48
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	210	ug/L		1300	08/10/21 15:00	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/10/21 15:00	KMC	EPA 200.8 REV 5.4

Sample: EH00244-19
Name: 19. Room 6089 Restroom
Alias: ASL-6089-RRF-9

Sampled: 07/29/21 06:47
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	62	ug/L		1300	08/10/21 15:02	KMC	EPA 200.8 REV 5.4
Lead	2.2	ug/L		15	08/10/21 15:02	KMC	EPA 200.8 REV 5.4

Sample: EH00244-20
Name: 20. Room 6088 Restroom
Alias: ASL-6088-RRF-10

Sampled: 07/29/21 06:47
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	78	ug/L		1300	08/10/21 15:03	KMC	EPA 200.8 REV 5.4
Lead	8.4	ug/L		15	08/10/21 15:03	KMC	EPA 200.8 REV 5.4

PDC Laboratories, Inc.

ANALYTICAL RESULTS

Sample: EH00244-21
Name: 21. Room 6086
Alias: ASL-6068-CF-6

Sampled: 07/29/21 06:43
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	52	ug/L		1300	08/10/21 15:05	KMC	EPA 200.8 REV 5.4
Lead	< 1.0	ug/L		15	08/10/21 15:05	KMC	EPA 200.8 REV 5.4

Sample: EH00244-22
Name: 23. Hall By 6087
Alias: ASL-H6087-EWC-4

Sampled: 07/29/21 06:43
Received: 08/02/21 12:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	160	ug/L			08/10/21 15:06	KMC	EPA 200.8 REV 5.4

NOTES

Specifications regarding method revisions and method modifications used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

Josh Lemon